

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-1130:206 Page 1 of 1

CATEGORY: Heat Detector

LISTEE: *Honeywell International Inc., 1500 W. Dundee Road, Arlington Heights, IL 60004-1472
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

DESIGN: Models TC808B1002, TC808B1025, TC808B1041, TC808B1066 Electronic fixed temperature heat detectors and Models TC808B1010, TC808B1033, and TC808B1058 electronic rate-of-rise with fixed temperature heat detector. All are rated 135°F fixed temperature detectors except high temperature sensor Model TC808B1066 rated as 190°F fixed temperature. All rate-of rise with fixed temperature detectors respond to greater than 15°F/min. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as electronic fixed temperature and rate-of-rise with fixed temperature heat detectors for use with separately listed compatible bases and fire alarm control units. Models TC808B1041, TC808B1058 and TC808B1066 are listed as intelligent sensors requiring compatible addressable communications to function properly and must be connected to listed-compatible bases and fire alarm control units. These devices are intended for installation on the ceiling.

*Rev. 06-14-2003KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND, Senior Deputy
Program Manager**